

Accessible Parking Committee Notes
Sub-Committee of Fox Valley Advocacy Coalition
Thompson Community Center on Lourdes

04/09/19 Meeting Notes

Attending: Jane Young, Jill Gretzinger, John Jenkins

- Jill reported she recently checked the parking situation at Liberty Hall in Kimberly. There has been no changes. Jill will contact our contact person at the Village of Kimberly.
- The ADA Technical Assistance Center was contacted regarding how spaces should be counted at Theda Care Behavioral Health. According to the technical assistance center:
 - When counting spaces in a parking lot you count lot by lot
 - If a lot is separated by a road or other type of barrier, it is viewed as a separate lot.
 - If one continuous lot, count all spots including employee parking to determine number of spots required.
 - Employee parking lots have the same standards as parking for the public, not exclusions for employee parking
- Currently, Theda Care Behavioral Health appears to have the correct number of spots, but are missing van signage and four spots have no access aisles. Jill will contact the Facilities Manager at Theda Care.
- Advance Auto Parts in Appleton is non-compliant. No upright signage, not correct number of spots. Will send to City of Appleton.
- A T & T on Calumet is not in compliance. No van signage or accessible van spot. Will send them a letter.
- John noted Gregorski has still not replaced the signage that disappeared.
- Next meeting of the committee will be Tuesday, May 14 at 10:30am. at the Easter Seals office.